SR Water Component Validations

Sec.	EA1		C2		W2		EA3		Beam Dump		C4		W4		EA5		Beam Dump		TR5		Cooling Box US		Cooling Box DS		EA6		TR6		Other				Validators
	off	on	off	on	off	on	off	on	off	on	off	on	off	on	off	on	off	on	off	on	off	on	off	on	off	on	off	on	off	on	off	on	Initials
1		X		X		X		X				X		X		X				X		X		X									RAF, RRB
2		X		X		X		X				X		X		X				X		X		X									RAF, RRB
3		X		X		X		X				X		X		X		X		X		X		X									RAF, RRB
4		X		X		X		X				X		X		X		X		X		X		X									RAF, RRB
5		X		X		X		X				X		X		X				X		X		X									RAF, RRB
6		X		X		X		X				X		X		X				X		X		X									RAF, RRB
7		X		X		X		X				X		X		X				X		X		X									RAF, RRB
8		X		X		X		X				X		X		X				X		X		X									RAF, RRB
9		X		X		X		X				X		X		X				X		X		X									RAF, RRB
10		X		X		X		X				X		X		X				X		X		X									RAF, RRB
11		X		X		X		X				X		X		X		X		X		X		X		X							RAF, RRB
12		X		X		X		X				X		X		X				X		X		X									RAF, RRB
13		X		X		X		X				X		X		X				X		X		X									RAF, RRB
14		X		X		X		X				X		X		X				X		X		X									RAF, RRB
15		X		X		X		X				X		X		X				X		X		X									RAF, RRB
16		X		X		X		X				X		X		X				X		X		X									RAF, RRB
17		X		X		X		X				X		X		X				X		X		X									RAF, RRB
18		X		X		X		X				X		X		X				X		X		X									RAF, RRB
19		X		X		X		X				X		X		X				X		X		X									RAF, RRB
20		X		X		X		X				X		X		X				X		X		X									RAF, RRB
21		X		X		X		X				X		X		X		X		X		X		X									RAF, RRB
22		X		X		X		X				X		X		X				X		X		X									RAF, RRB
23		X		X		X		X				X		X		X		X		X		X		X									RAF, RRB
24		X		X		X		X				X		X		X		X		X		X		X									RAF, RRB
25		X		X		X		X				X		X		X		X		X						X		X					RAF, RRB
26		X		X		X		X		X		X		X		X		X		X		X		2.08gpm									RAF, RRB
27		X		X		X		X		X		X		X		X		X		X						X		X					RAF, RRB
28		X		X		X		X		X		X		X		X		X		X						X		X					RAF, RRB
29		X		X		X		X		X		X		X		X		X		X						X		X					RAF, RRB
30		X		X		X		X		X		X		X		X		X		X		X		X									RAF, RRB
31		X		X		X		X		X		X		X		X		X		X		X		X									RAF, RRB
32		X		X		X		X				X		X		X				X		X		X									RAF, RRB
33		X		X		X		X				X		X		X				X		X		X									RAF, RRB
34		X		X		X		X				X		X		X				X		X		X		X				Wt Scraper			RAF, RRB
35		X		X		X		X				X		X		X				X		X		X						TR DCC			RAF, RRB
36		X		X		X		X				X		X		X		X		X								X		TR RF	V SCR - NF x 2		RAF, RRB
37		X		X		X		X		X		X		X		X		X		X								X		TR RF	RF x2		RAF, RRB
38		X		X		X		X		X		X		X		X		X		X								2.0gpm		CF / V SCR	RF x2		RAF, RRB
39		X		X		X		X		X		X		X		X		X		X						X		X		CF / H SCR	TR6a		RAF, RRB
40		X		X		X		X		X		X		X		X		X		X								X		CF / HF SCR	RF x3	TR RF	RAF, RRB

Circuit 1
Circuit 2
Circuit 3
Circuit 4

Validation Instructions for disconnected components

1. Make sure all components are connected, leak tight and valves are open
2. Attach ultrasonic flowmeter to the return side of component
3. Compare reading to reference value
4. Initial the flow validation column

Responsible Engineer: G. Putnam 9/16/04

Group Leader: L. Mann 9/16/04

Date: _____