

---

# TWL Calibration Data Summary

---

Serial Number: 9800640

---

**Full-Scale Flow Rate:** 500  
(yields 20mA output)

**Zero Flow Rate:** (yields 4mA output)

**Bridge Resistance:** 351.6 ohms

**Full-Scale Bridge Output:** 2.0453 mV/V

**Calibration Resistor (R7):** 47363 ohms

**Calibration Voltage:** 0.904 volts

**Calibration Flow Rate:** 475.4

**Calibration Current:** 19.21 mA

**Zero Switch Setting:** 0

**TB3 Jumper Position:** + (POSITIVE)

**Span Switch Setting - Undamped:** 0

**Span Switch Setting - Damped:** 8

**Additional Information:**

---

RF2  
SUP

FLOW METER DATA  
SAVE FOR INSTALLATION  
AND RECORDS