

EPICS Database Principles

Andrew Johnson
APS Engineering Support Division

June 2010

USPAS EPICS Course

Outline

- Records
- Fields and field types
- Record Scanning
- Input and Output record types
- Links, link address types
- Connecting records together
- Protection mechanisms
- Alarms, dead-bands, simulation and security



Database = Records + Fields + Links

- A control system using EPICS will contain one or more IOCs
- Each IOC loads one or more Databases telling it what to do
- A Database is a collection of Records of various types
- A Record is an object with:
 - A unique name
 - A behavior defined by its record type (class)
 - Controllable properties (fields)
 - Optional associated hardware I/O (device support)
 - Links to other records



Record Activity

- Records are active — they can do things:
 - Get data from other records or from hardware
 - Perform calculations
 - Check values are in range & raise alarms
 - Put data to other records or to hardware
 - Activate or disable other records
 - Wait for hardware signals (interrupts)
- What a record does depends upon its record type and the settings of its fields
- No action occurs unless a record is processed



How is a Record implemented?

- A 'C' structure with a data member for each record field
 - All records start with a standard set of fields (dbCommon) that the system needs, including pointers to record type information
- A record definition within a database provides
 - Record name
 - The record's type
 - Values for each design field
- A record type provides
 - Definitions of all the fields
 - Code which implements the record's behavior
- New record types can be added to an application as needed



One view of a Record

Window No. 0

ao: DemandTemp

DESC	STRING	Descriptor	Temperature Demand
ASG	STRING	Access Security Group	
SCAN	MENU	Scan Mechanism	1 second
PINI	MENU	Process at iocInit	NO
PHAS	INTEGER	Scan Phase	0
EVNT	INTEGER	Event Number	0
TSE	INTEGER	Time Stamp Event	0
TSEL	INLINK	Time Stamp Link	Form
DTYP	DEVICE	Device Type	Soft Channel
OUT	OUTLINK	Output Specification	Form
DISV	INTEGER	Disable Value	1
SDIS	INLINK	Scanning Disable	Form
ACKT	MENU	Alarm Ack Transient	YES
DISS	MENU	Disable Alarm Sevrty	NO_ALARM
PRIO	MENU	Scheduling Priority	LOW
UDF	INTEGER	Undefined	1
FLNK	FWDLINK	Forward Process Link	Form
VAL	REAL	Desired Output	0
OROC	REAL	Output Rate of Chang	0
DOL	INLINK	Desired Output Loc	UserDemand NPP NMS Form
OMSL	MENU	Output Mode Select	supervisory
OIF	MENU	Out Full/Incremental	Full

Close

A graphical view of a Record

The image displays two side-by-side windows from a control system interface. The left window is a graphical representation of a record, and the right window is an 'Inspector' for that record.

Record Graphical View:

ao
DemandTemp

DESC=Temperature Demand
SCAN=1 second
EGU=Celcius
HOPR=80
LOPR=20
DRVH=100
DRVL=0
DTYP=Soft Channel
PINI=NO
DOL=UserDemand

NPP NMS Σ DOL

Inspector - DemandTemp

R DemandTemp (ao)


Group Alphabetical DBD Order

GUI_COMMON		GUI_COMMON	
DESC		Temperature Dem...	
ASG			
UDF		1	
GUI_LINKS		GUI_LINKS	
DTYP		Soft Channel	
FLNK			
GUI_INPUTS		GUI_INPUTS	
SIOL			
SIML			
SIMS		<none>	
GUI_OUTPUT		GUI_OUTPUT	
VAL			
OUT			
OROC			
DOL		UserDemand	

Comment

No object selected Frozen

Another graphical view of a Record



The small *CapFast* symbol for an Analogue Output record

The IOC's view

The full .db file entry for an Analogue Output Record

```
record(ao,"DemandTemp") {
  field(DESC,"Temperature")
  field(ASG,"")
  field(SCAN,"Passive")
  field(PINI,"NO")
  field(PHAS,"0")
  field(EVNT,"0")
  field(DTYP,"VMIC 4100")
  field(DISV,"1")
  field(SDIS,"")
  field(DISS,"NO_ALARM")
  field(PRIO,"LOW")
  field(FLNK,"")
  field(OUT,"#C0 S0")
  field(OROC,"0.0e+00")
  field(DOL,"")
  field(OMSL,"supervisory")
  field(OIF,"Full")
  field(PREC,"1")
  field(LINR,"NO CONVERSION")
  field(EGUF,"100")
  field(EGUL,"0")
  field(EGU,"Celcius")
  field(DRVH,"100")
  field(DRVL,"0")
  field(HOPR,"80")
  field(LOPR,"10")
  field(HIHI,"0.0e+00")
  field(LOLO,"0.0e+00")
  field(HIGH,"0.0e+00")
  field(LOW,"0.0e+00")
  field(HHSV,"NO_ALARM")
  field(LLSV,"NO_ALARM")
  field(HSV,"NO_ALARM")
  field(LSV,"NO_ALARM")
  field(HYST,"0.0e+00")
  field(ADEL,"0.0e+00")
  field(MDEL,"0.0e+00")
  field(SIOL,"")
  field(SIML,"")
  field(SIMS,"NO_ALARM")
  field(IVOA,"Continue normally")
  field(IVOV,"0.0e+00")
}
```

This shows only the design fields; there are other fields which are used only at run-time

Fields are for...

- Defining
 - What causes a record to process
 - Where to get/put data from/to
 - How to turn raw I/O data into a numeric engineering value
 - Limits indicating when to report an alarm
 - When to notify value changes to a client monitoring the record
 - A Processing algorithm
 - Anything else which needs to be set for each record of a given type
- Holding run-time data
 - Input or output values
 - Alarm status, severity and acknowledgments
 - Processing time-stamp
 - Other data for internal use

Field types — fields can contain:

- Integers
 - char, short or long
 - signed or unsigned
- Floating-point numbers
 - float or double
- Fixed length strings
 - maximum useful length is 40 characters
- Enumerated/menu choices
 - select one of up to 16 strings
 - stored as a short integer
- Arrays of any of the above types
- Links
 - to other records in this or other IOCs
 - to hardware signals (device support)
 - provide a means of getting or putting a value
- Other private data
 - not accessible remotely

All Records have these design fields

NAME 60 Character unique name (using more than 28 can cause problems)

DESC 40 Character description

ASG Access security group

SCAN Scan mechanism

PHAS Scan order (phase)

PINI Process during IOC initialization?

PRIO Scheduling priority

SDIS Scan disable input link

DISV Scan disable value

DISS Disabled severity

FLNK Forward link

All Records have these Run-time fields

PROC Force processing

PACT Process active

STAT Alarm status

SEVR Alarm severity

TPRO Trace processing

UDF Non-zero if record value undefined

TIME Time when record was last processed



Record Scanning

- `SCAN` field is a menu choice from
 - Periodic — 0.1 seconds .. 10 seconds (extensible)
 - I/O Interrupt (if device supports this)
 - Soft event — `EVNT` field
 - Passive (default)
- The number in the `PHAS` field allows the relative order in which records are processed within a scan to be controlled
 - Records with `PHAS=0` are processed first
 - Then those with `PHAS=1` , `PHAS=2` etc.
- The `PINI` field chooses if/when records get processed once at IOC startup or when paused
 - No, Yes, Run, Running, Pause, Paused
- `PRIO` field selects Low/Medium/High priority for Soft event and I/O Interrupts
- A record is also processed whenever any value is written to its `PROC` field

Input records often have these fields

INP *Input link*

DTYP *Device type*

RVAL *Raw data value*

VAL *Engineering value*


LOPR *Low operator range*

HOPR *High operator range*

Analogue I/O records have these fields:

<i>EGU</i>	<i>Engineering unit string</i>
<i>LINR</i>	<i>Unit conversion control: No conversion, Linear, Slope, breakpoint table name</i>
<i>EGUL</i>	<i>Low engineering value</i>
<i>EGUF</i>	<i>High engineering value</i>
<i>ESLO</i>	<i>Unit conversion slope</i>
<i>EOFF</i>	<i>Unit conversion offset</i>

Periodically Scanned Analog Input



- Analogue Input “Temperature”
- Reads from the Xycom XY566 ADC Card 0 Signal 0
- Gets a new value every second
- Data is converted from ADC range to 0..120 Celsius

Interrupt Scanned Binary Input

```
bi
VentValve
-----
DTYP=AB-Binary Input
INP=#L0 A0 C3 S5
SCAN=I/O Intr
PHAS=0
ZNAM=Closed
ZSV=NO_ALARM
ONAM=Open
OSV=MAJOR
```

- Binary Input “VentValve”
- Reads from Allen-Bradley TTL I/O Link 0, Adaptor 0, Card 3, Signal 5
- Processed whenever value changes
- 0 = “Closed”, 1 = “Open”
- Major alarm when valve open

Most output records have these fields

<i>OUT</i>	<i>Output link</i>
<i>DTYP</i>	<i>Device type</i>
<i>VAL</i>	<i>Engineering value</i>
<i>RVAL</i>	<i>Raw output value</i>
<i>DOL</i>	<i>Input link to fetch output value</i>
<i>OMSL</i>	<i>Output mode select:</i> Supervisory, Closed Loop
<i>LOPR</i>	<i>Low operator range</i>
<i>HOPR</i>	<i>High operator range</i>

Analogue outputs also have these fields:

<i>OROC</i>	<i>Output rate of change</i>
<i>OIF</i>	<i>Incremental or Full output</i>
<i>OVAL</i>	<i>Output value</i>
<i>DRVH</i>	<i>Drive high limit</i>
<i>DRVL</i>	<i>Drive low limit</i>
<i>IVOA</i>	<i>Invalid output action</i>
<i>IVOV</i>	<i>Invalid output value</i>
<i>RBV</i>	<i>Read-back value</i>



Passive Binary Output

```
bo
Solenoid
-----
DTYP=XY220
OUT=#C0 S12
SCAN=Passive
PHAS=0
ZNAM=Locked
ONAM=Unlocked
OMSL=supervisory
```

- Binary Output “Solenoid”
- Controls Xycom XY220 Digital output Card 0 Signal 12
- Record is only processed by
 - Channel Access ‘put’ to a PP field (e.g. .VAL)
 - Another record writes to a PP field
 - Forward Link from another record
 - Another record reads this with PP

Break time...

5 Minute break



Links

A link is a type of field, and is one of

- Input link
 - Fetches data
- Output link
 - Writes data
- Forward link
 - Points to the record to be processed once this record finishes processing

Input and Output links may be...

- Constant numeric value, e.g.:
 - 0
 - 3.1415926536
 - 1.6e-19
- Hardware link
 - A hardware I/O signal selector, the format of which depends on the device support layer
- Process Variable link — the name of a record, which at run-time is resolved into
 - Database link
 - Named record is in this IOC
 - Channel Access link
 - Named record not found in this IOC

Hardware links

<code>VME_IO</code>	<code>#Cn Sn @parm</code> Card, Signal
<code>INST_IO</code>	<code>@parm</code>
<code>CAMAC_IO</code>	<code>#Bn Cn Nn An Fn @parm</code> Branch, Crate, Node, Address, Function
<code>AB_IO</code>	<code>#Ln An Cn Sn @parm</code> Link, Adapter, Card, Signal
<code>GPIB_IO</code>	<code>#Ln An @parm</code> Link, Address
<code>BITBUS_IO</code>	<code>#Ln Nn Pn Sn @parm</code> Link, Node, Port, Signal
<code>BBGPIB_IO</code>	<code>#Ln Bn Gn @parm</code> Link, Bitbus Address, GPIB Address
<code>VXI_IO</code>	<code>#Vn Cn Sn @parm</code>
<code>or</code>	<code>#Vn Sn @parm</code> Frame, Slot, Signal

Database links

- These comprise:
 - The name of a record in this IOC
`myDb:myRecord`
 - An optional field name
 - `.VAL` (default)
 - Process Passive flag
 - `NPP` (default), or `PP`
 - Maximize Severity flag
 - `NMS` No maximize severity (default)
 - `MS` Maximize severity
 - `MSS` Maximize Status and Severity (new in R3.14.11)
 - `MSI` Maximize Severity when Invalid (new in R3.14.11)
- Example
 - `M1:current.RBV NPP MS`
- NB: Database links with the `PP` flag set never wait for asynchronous record processing to finish, so an input link that triggers a read from slow hardware will return the previous data in that record

Channel Access links

- Similar to a database link
- Names a record that does not have to be in this IOC
- Uses Channel Access to communicate with the record
 - Just like any other CA client, even for local records
 - Input sets up a CA monitor on the channel
- May include a field name (default `.VAL`)
- PP Link flags are ignored
 - Input links are always `NPP`
 - Output links follow `PP` attribute of destination field
 - These are how all CA clients behave
- MS Link flags apply to Input links
 - Input links honor `NMS (default)/MS/MSS/MSI`
 - Output links are always `NMS`
- Additional flags for CA links
 - `CA` Forces a “local” link to use CA
 - `CP` On input link, process this record on CA monitor event
 - `CPP` Like `CP` but only process me if `SCAN` is Process Passive

Link flag summary

Type	Input Links	Output Links
DB	PP or NPP NMS, MS, MSS or MSI	PP or NPP NMS, MS, MSS or MSI
CA	Always NPP MS or NMS CA forces link type CP process record on change CPP like CP but only process if SCAN=Passive	PP set by destination field Always NMS CA forces link type

Chapter 5 of the IOC Application Developer's Guide covers record links and scanning in detail, and is worth reading.

Device Support

- Records do not access hardware directly
- The Device Support layer performs I/O operations on request
 - Each device support performs I/O for one record type
- A record's DTYP field determines which device support it uses
 - Most record types default to Soft Channel support if you don't set DTYP
- The device support selected determines the format of the link (INP or OUT field) containing the device address
- Adding new device support does not require any changes or recompilation of the record type code
- Device support often calls other software to do work for it (Driver Support or other libraries)

Synchronous vs Asynchronous I/O

- IOC rules do not allow device support to busy-wait (i.e. delay record processing while waiting for the results of a slow I/O operation)
 - Fast I/O can be handled synchronously
 - Slow operations must operate asynchronously
- Register-based VME/PCI cards usually give an immediate response, so will be synchronous
 - When called, a synchronous read or write call to device support performs all I/O needed before returning
- Serial, network or field-bus I/O usually takes some time (>10ms) to return data, so should be asynchronous
 - Asynchronous device support starts an I/O operation when the record calls it, flagging it as incomplete by setting `PACT` to true before returning
 - When the results are available (discovered by a CPU interrupt or polling background thread), the device support must call the record's `process()` routine to finish the record processing operations


Soft Device Support

- “Hard” input and output records do hardware I/O via device support
- “Soft” records access data from other records via DB or CA links
- 2 or 3 kinds of support are provided in recent R3.14 releases:
 - Soft Channel
 - Get/Put VAL through link, no units conversion performed
 - Async Soft Channel (currently output records only)
 - Put VAL through CA link, no conversions, wait for completion
 - Raw Soft Channel
 - Inputs
 - Get RVAL via input link
 - Convert RVAL to VAL (record-type specific)
 - Outputs
 - Convert VAL to RVAL (record-type specific)
 - Put RVAL to output link


Forward links

- Usually a Database link, referring to a record in same IOC
- No flags (`PP`, `MS` etc.), although VDCT includes them erroneously
- Destination record is only processed if its `SCAN` field is `Passive`
- Does not pass a value, just causes subsequent processing
- Forward linking to another IOC via Channel Access is possible, but the link must explicitly name the `PROC` field of the remote record
 - In this case only, the remote record does not need to have `SCAN` set to `Passive`


Processing chains



Which record is never processed?




How often is Input_1 processed?



The PACT field

- Every record has a boolean run-time field called `PACT` (Process Active)
- `PACT` breaks loops of linked records
- It is set to true early in the act of processing the record (but it's not the first thing that the process routine does)
 - `PACT` should always be true whenever a link in that record is used to get/put a value
- `PACT` gets reset to false after all record I/O and forward link processing are finished
- A `PP` link can never make a record process if it has `PACT` true
 - Input links will take the current field value
 - Output links just put their value to the field

What happens here?



Preventing records from processing


- It is useful to be able to stop an individual record from processing on some condition
- Before record-specific processing is called, a value is read through the `SDIS` input link into `DISA` (which defaults to 0 if the link is not set)
- If `DISA=DISV`, the record will *not* be processed
- The default value of the `DISV` field is 1
- A disabled record may be put into an alarm state by giving the desired severity in the `DISS` field
- The `FLNK` of a disabled record is never triggered

Break time...

5 Minute break




Order of Operations (Synchronous I/O)




1. Every 0.1 seconds, iocCore will attempt to process the Output_1 record
2. The `Output_1.PACT` field is currently False, so the record is quiescent and can be processed
3. If set, the `Output_1.SDIS` link would be read into `Output_1.DISA`
4. Since `DISA≠DISV`, the `ao` record type's `process()` routine is called

Order of Operations (Synchronous I/O)




5. The ao's process() routine checks the `Output_1.OMSL` field; it is `closed_loop`, so
6. It sets `Output_1.PACT` to `True`, then
7. Reads a value through the `Output_1.DOL` link
8. The `Output_1.DOL` link contains `Calculation_1.VAL PP` so this first attempts to process the `Calculation_1` record

Order of Operations (Synchronous I/O)




9. The `Calculation_1.SCAN` field is `Passive` and `Calculation_1.PACT` is `False`, so processing is possible
10. If set, the `Calculation_1.SDIS` link would be read into `DISA`
11. Since `DISA≠DISV`, the `calc` record type's `process()` routine is called

Order of Operations (Synchronous I/O)




12. The calc's process() routine sets `Calculation_1.PACT` to True, then
13. Starts a loop to read values from the links `INPA` through `INPL`
14. The `Calculation_1.INPA` link is set to `Input_1.VAL PP` so this first attempts to process the `Input_1` record

Order of Operations (Synchronous I/O)




15. The `Input_1.SCAN` field is `Passive` and `Input_1.PACT` is `False`, so processing is possible
16. If set, the `Input_1.SDIS` link is read into the `Input_1.DISV` field
17. Since `DISA≠DISV`, the `ai` record type's `process()` routine is called
18. The `ai process()` calls the associated device support to read a value from the hardware it's attached to

Order of Operations (Synchronous I/O)




19. The device support is synchronous, so it puts the hardware input value into the `Input_1.RVAL` field and returns to the `ai` record's `process()` code
20. The `Input_1.PACT` field is set to True
21. The record's timestamp field `Input_1.TIME` is set to the current time
22. The raw value in `Input_1.RVAL` is converted to engineering units, smoothed, and the result put into the `Input_1.VAL` field

Order of Operations (Synchronous I/O)




23. The `Input_1.VAL` is checked against alarm limits and monitor dead-bands, and appropriate actions are taken if these are exceeded
24. If the Forward Link field `Input_1.FLNK` is set, an attempt is made to process the record it points to
25. The `Input_1.PACT` field is set to False, and the `process()` routine returns control to the `Calculation_1` record

Order of Operations (Synchronous I/O)




26. The value read through the `Calculation_1.INPA` link is copied into the `Calculation_1.A` field
27. The Calculation record type's `process()` routine continues to loop, reading its input links
28. In this example only the `INPA` link is set, so the routine finishes the loop and evaluates the `Calculation_1.CALC` expression (not shown)
29. The result of the expression is put in the `Calculation_1.VAL` field

Order of Operations (Synchronous I/O)




30. The record's timestamp field `Calculation_1.TIME` is set to the current time
31. `Calculation_1.VAL` is checked against alarm limits and monitor dead-bands, and appropriate action is taken if these are exceeded
32. If the Forward Link field `Calculation_1.FLNK` is set, an attempt is made to process the record it points to
33. The `Calculation_1.PACT` field is set to False, and the `process()` routine returns control to the `Output_1` record

Order of Operations (Synchronous I/O)



34. The value read through the `Output_1.DOL` link would now be forced into the range `DRVL..DRVH` if those fields were set, but they aren't so it's copied to the `Output_1.VAL` field unchanged
35. The `Output_1.VAL` value is converted from engineering to raw units and placed in `Output_1.RVAL`
36. `Output_1.VAL` is checked against alarm limits and monitor dead-bands, and appropriate action is taken if these are exceeded
37. The associated device support is called to write the value to the hardware

Order of Operations (Synchronous I/O)




- 38. The device support is synchronous, so it outputs the value to the attached hardware and returns
- 39. The record's timestamp field `Output_1.TIME` is set to the current time
- 40. If the Forward Link field `Output_1.FLNK` is set, an attempt is made to process the record it points to
- 41. The `Output_1.PACT` field is set to False, and the `process()` routine returns

How are records given CPU time?

Several IOC tasks are used:

- callback (3 priorities) — I/O Interrupt
- scanEvent — Soft Event
- scanPeriod — Periodic
 - A separate task is used for each scan period
 - Faster scan rates are given a higher task priority (if supported by the IOC's Operating System)
- Channel Access tasks use lower priority than record processing
 - If a CPU spends all its time doing I/O and record processing, you may be unable to control or monitor the IOC via the network

What could go wrong here?



Lock-sets


- Prevent records from being processed simultaneously by two different scan tasks
 - PACT can't do that, it isn't set early enough and is not a Mutex
- A lock-set is a group of records interconnected by database links
- Lock-sets are determined automatically by the IOC at start-up, or whenever a database link is added, deleted or modified
- You can split two linked records into different lock sets by making the link(s) joining them into Channel Access ones, using the `CA` flag
 - Remember that CA links behave slightly differently than DB links, make sure your design still works!

Alarms

- Every record has the fields
 - SEVR Alarm Severity
 - NONE, MINOR, MAJOR, INVALID
 - STAT Alarm Status (reason)
 - READ, WRITE, UDF, HIGH, LOW, STATE, COS, CALC, DISABLE, etc.
- Most numeric records compare VAL against the HIHI, HIGH, LOW and LOLO fields after its value has been determined
- The HYST field sets a hysteresis to prevent alarm chattering
- A separate alarm severity can be set for each numeric limit exceeded
 - Fields HHSV, HSV, LSV, and LLSV
- Discrete (binary) records can raise alarms on entering a particular state, or on a change of state (COS)

Change Notification: Monitor Dead-bands

- Channel Access notifies clients that are monitoring a numeric record when
 - VAL changes by more than the value in field:
 - MDEL *Value monitors*
 - ADEL *Archive monitors*
 - Record's Alarm Status changes
 - HYST *Alarm hysteresis*
- The Analogue Input record has a smoothing filter to reduce noise on the input signal (SMOO)




Breakpoint Tables

- Analogue Input and Output records can do non-linear conversions from/to the raw hardware value
- Breakpoint tables interpolate values from a given table
- To use, set the record's LINR field to the name of the breakpoint table you want to use
- Example breakpoint table (in some loaded .dbd file)

```
breaktable(typeKdegC) {  
    0.000000    0.000000  
    299.268700  74.000000  
    660.752744 163.000000  
    1104.793671 274.000000  
    1702.338802 418.000000  
    2902.787322 703.000000  
    3427.599045 831.000000  
    ...  
}
```

Type J Thermocouple



Simulation

- Input and output record types often allow simulation of hardware interfaces
 - SIML Simulation mode link
 - SIMM Simulation mode value
 - SIOL Simulation input link
 - SVAL Simulated value
 - SIMS Simulation alarm severity
- Before calling device support, records read SIMM through the SIML link
- If SIMM=YES (1) or RAW (2) the device support is not used; record I/O is done through the SIOL link and SVAL field instead
- An alarm severity can be set whenever simulating, given by SIMS field

Access Security

- A networked control system must have the ability to enforce security rules
 - Who can do what from where, and when?
- In EPICS, security is enforced by the CA server (the IOC or gateway)
- A record is placed in the Access Security Group named in its `ASG` field
 - DEFAULT is used if no group name is given
- Rules are specified for each group to determine whether a CA client can read or write to records in that group, based on
 - Client user ID
 - Client host-name or IP address
 - Access Security Level of the field addressed
 - Values read from the database

Access Security Configuration File

- Security rules are loaded from an Access Security Configuration File, for example:

```
UAG(users) {user1, user2}
HAG(hosts) {host1, host2}
ASG(DEFAULT) {
    RULE(1, READ)
    RULE(1, WRITE) {
        UAG(users)
        HAG(hosts)
    }
}
```

- If no security file is loaded, Security will be turned off and nothing refused
- For more details and the rule syntax, see Chapter 8 of the IOC Application Developers Guide